

# FORM FOR COMMENT FOR 2014 NATIONAL ELECTRICAL CODE®

## INSTRUCTIONS — PLEASE READ CAREFULLY

Type or print **legibly**. Use a separate copy for each comment. Limit each comment to a **SINGLE** section. All comments **must be received by NFPA by 5 p.m., EDST, Wednesday, October 17, 2012**, to be considered for the 2014 National Electrical Code. Comments received after 5:00 p.m., EDST, Wednesday, October 17, 2012, will be returned to the submitter.

**For technical assistance, please call NFPA at 1-800-344-3555.**

## FOR OFFICE USE ONLY

Log #: \_\_\_\_\_

Date Rec'd: \_\_\_\_\_

Please indicate in which format you wish to receive your ROP/ROC  electronic  paper  download  
(Note: If choosing the download option, you must view the ROP/ROC from our website; no copy will be sent to you.)

Date 15 OCT 2012 Name JOHN C. WILES, JR. Tel. No. 575-646-6105

Company SOUTHWEST TECHNOLOGY DEVELOPMENT INSTITUTE/NMSU Email jwiles@nmsu.edu

Street Address 3705 RESEARCH DRIVE City LAS CRUCES State NM Zip 88003

\*\*\*If you wish to receive a hard copy, a street address **MUST** be provided. Deliveries cannot be made to PO boxes.

Please indicate organization represented (if any) PV INDUSTRY FORUM

1. Section/Paragraph 690.5(A)

2. Comment on Proposal No. (from ROP): 4-214

3. Comment recommends (check one):  new text  revised text  deleted text

4. Comment (include proposed new or revised wording, or identification of wording to be deleted): [Note: Proposed text should be in legislative format; i.e., use underscore to denote wording to be inserted (inserted wording) and strike-through to denote wording to be deleted (~~deleted wording~~).

### Revise 4-214 as shown

(A) **Ground-Fault Detection and Interruption.** The ground-fault protection device or system shall:

~~(1) Determine the pv input circuit has isolation prior to export of current,~~

(1) ~~(2)~~ Be capable of detecting a ground-fault in the PV array dc current carrying conductors and components including any intentionally grounded conductors,

(2) ~~(3)~~ Interrupt the flow of fault current, ~~and~~

(3) ~~(4)~~ Provide an indication of the fault, and

(4) Be listed for providing PV ground fault protection.

5. **Statement of Problem and Substantiation for Comment:** (Note: State the problem that would be resolved by your recommendation; give the specific reason for your Comment, including copies of tests, research papers, fire experience, etc. If more than 200 words, it may be abstracted for publication.)

Undetected ground faults on grounded conductors have caused several fires in PV systems over the last half decade. Clearly ground fault protection (GFP) capabilities need to be improved in new PV systems. As result, we applaud and support the Code Making Panel in addressing this important issue. In the end, however, the ground fault protection sensitivity requirements in the standards, which are too lenient for modern PV systems, need to be updated to resolve this problem. The modifications proposed in this comment will help drive changes to the standards so as to eliminate this problem and will require that GFP used in PV systems comply with these new standards.

The modifications included in Proposal 4-214 successfully address several issues with the NEC requirements for GFP. First, the 2011 Code is sometimes interpreted to require a current based detection method because it reads GFP "...shall be capable of detecting a ground-fault current". Unfortunately, current based detection methods are not always the most effective GFP solutions for all PV system designs. Second, some inspectors view the 2011 Code as not allowing for insulation resistance measurements on grounded conductors in solidly grounded systems because it would require disconnecting these conductors from ground during the measurement. Insulation resistance measurements can be a very effective GFP method in some system designs and will help improve detection of grounded conductor ground faults. It is tremendous that the Code Making Panel has addressed both of these issues with Proposal 4-214 by removing current from requirement #2 and adding "for measurement purposes or" to the supporting paragraph.

Now then, the new 2014 language does raise a new problem as result of this proposal. It requires the use of insulation resistance measurements in all systems. This method is not universally effective and will not be the best GFP for all PV system designs. Furthermore, as new technologies come to market, GFP methods superior to insulation resistance measurements may emerge. We want the 2014 NEC to address the inadequacies of present GFP once and for all and not legislate the use of a specific solution. For this reason, we would request that you adapt 690.5(A) to read as modified above. This will stimulate UL 1741 to be updated to reflect the needs for improved GFP in PV systems and to ensure that the new functional requirements are met without requiring a

specific implementation/solution.

Lastly, the statement of "... prior to the export of current" is not enforceable. It is unclear how frequently this test would have to be performed. It could be interpreted to be: 1) before the system is turned on for the first time; 2) every night; or 3) every time the inverter starts up.


#### 6. Copyright Assignment

- (a)  I am the author of the text or other material (such as illustrations, graphs) proposed in the Comment.
- (b)  Some or all of the text or other material proposed in this Comment was not authored by me. Its source is as follows:  
(please identify which material and provide complete information on its source)

---

*I hereby grant and assign to the NFPA all and full rights in copyright in this Comment and understand that I acquire no rights in any publication of NFPA in which this Comment in this or another similar or analogous form is used. Except to the extent that I do not have authority to make an assignment in materials that I have identified in (b) above, I hereby warrant that I am the author of this Comment and that I have full power and authority to enter into this assignment.*

**Signature (Required)**



---

**PLEASE USE SEPARATE FORM FOR EACH COMMENT**

Mail to: Secretary, Standards Council · National Fire Protection Association  
1 Batterymarch Park · Quincy, MA 02169-7471 OR  
Fax to: (617) 770-3500 OR Email to: [proposals\\_comments@nfpa.org](mailto:proposals_comments@nfpa.org)

10/15/2012